



<http://www.enerpro-inc.com/>
info@enerpro-inc.com

5780 Thornwood Drive
Goleta, CA 93117
(805) 683-2114

FCOG6100 Revision R Ordering Guide

FCOG6100 - - - - - - - - -
(See Note 5)

Customer Name

Date

Application Description

Customer Comments

NOTES

- 1. An auxiliary firing board is required.
- 2. Specify specific circuit type in comments field below.
- 3. Customer must supply 24 Vac or 30 VDC to FCOG6100.
- 4. For 50 or 60 Hz operation, specify "5/6". Otherwise, dash code is the mains frequency divided by 10 (120 Hz = 12, 400 Hz = 40, etc). Please specify in comments field.
- 5. Specify SCR mains voltage as the ac mains voltage divided by 10 (480 Vac = 48, 240 Vac = 24, etc).