



NOTES:

- 1 Switch is shown in the enable position. Close switch to begin ramp down and inhibit.
- 2 Switch is shown in the enable position. Open switch to instantly inhibit SCRs.

		ENERPRO	
Approvals	Date	CONNECTION DIAGRAM: 4-QUADRANT DC CONTROLLER	
dwn: ppd		Dwg. No.	
Version	6-14-01	E821	
		CUSTOMER:	Sheet 1 of 1